

## Lake Huron Water Treatment Plant 2010 Regulated Detected Contaminants Tables

Contaminant	Test Date	Units	Health Goal MCLG	Allowed Level MCL	Level Detected	Range of Detection	Violation yes/no	Major Sources in Drinking Water
<b>Inorganic Chemicals – Annual Monitoring at Plant Finished Water Tap</b>								
Fluoride	8/2010	ppm	4	4	1.40	0.56-1.40	no	Erosion of natural deposits; Water additive, which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate	8/23/2010	ppm	10	10	0.32	n/a	no	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Barium	6/9/2008	ppm	2	2	0.01	n/a	no	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
<b>Disinfectant Residuals and Disinfection By-Products – Monitoring in Distribution System</b>								
Total Trihalomethanes (TTHM)	Feb-Nov 2010	ppb	n/a	80	18.5	9.2-40.1	no	By-product of drinking water chlorination
Haloacetic Acids (HAA5)	Feb- Nov 2010	ppb	n/a	60	10.1	6.0-17.1	no	By-product of drinking water disinfection
Disinfectant (Total Chlorine residual)	Jan-Dec 2010	ppm	MRDGL 4	MRDL 4	0.78	0.70-0.88	no	Water additive used to control microbes

<b>2010 Turbidity – Monitored every 4 hours at Plant Finished Water Tap</b>			
Highest Single Measurement Cannot exceed 1 NTU	Lowest Monthly % of Samples Meeting Turbidity Limit of 0.3 NTU (minimum 95%)	Violation yes/no	Major Sources in Drinking Water
0.09 NTU	100%	no	Soil Runoff
Turbidity is a measure of the cloudiness of water. We monitor it because it is a good indicator of the effectiveness of our filtration system.			

<b>2010 Microbiological Contaminants – Monthly Monitoring in Distribution System</b>					
Contaminant	MCLG	MCL	Highest Number Detected	Violation yes/no	Major Sources in Drinking Water
Total Coliform Bacteria	0	Presence of Coliform bacteria > 5% of monthly samples	in one month		Naturally present in the environment.
<i>E.coli</i> or fecal coliform bacteria	0	A routine sample and a repeat sample are total coliform positive, and one is also fecal or <i>E. coli</i> positive.	entire year		Human waste and animal fecal waste.

<b>2008 Lead and Copper Monitoring at Customers' Tap</b>								
Contaminant	Test Date	Units	Health Goal MCLG	Action Level AL	90 <sup>th</sup> Percentile Value*	Number of Samples Over AL	Violation yes/no	Major Sources in Drinking Water
Lead	2008	ppb	0	15				Corrosion of household plumbing system; Erosion of natural deposits.
Copper	2008	ppm	1.3	1.3				Corrosion of household plumbing system; Erosion of natural deposits; Leaching from wood preservatives.
*The 90th percentile value means 90 percent of the homes tested have lead and copper levels below the given 90th percentile value. If the 90th percentile value is above the AL additional requirements must be met.								

Regulated Contaminant	Treatment Technique	Running annual average	Monthly Ratio Range	Violation Yes/No	Typical Source of Contaminant
Total Organic Carbon (ppm)	The Total Organic Carbon (TOC) removal ratio is calculated as the ratio between the actual TOC removal and the TOC removal requirements. The TOC was measured each month and because the level was low, there is no requirement for TOC removal.				Erosion of natural deposits

### 2010 Special Monitoring

Contaminant	MCLG	MCL	Level Detected	Source of Contamination
Sodium (ppm)	n/a	n/a	4.45	Erosion of natural deposits